

第V期最終処分場		2020年度									
		保有水					放流水				
整理番号	実測濃度 (pg/L)	試料における		毒性等価係数 TEF	※毒性当量 (pg-TEQ/L)	実測濃度 (pg/L)	試料における		毒性等価係数 TEF	※毒性当量 (pg-TEQ/L)	
		定量下限 (pg/L)	検出下限 (pg/L)				定量下限 (pg/L)	検出下限 (pg/L)			
PCDDs	1,3,6,8-TeCDD	0.47	0.29	0.09	-	-	0.63	0.29	0.09	-	-
	1,3,7,9-TeCDD	-0.19	0.29	0.09	-	-	0.46	0.29	0.09	-	-
	2,3,7,8-TeCDD	ND	0.29	0.09	1	0	ND	0.29	0.09	1	0
	TeCDDs	0.66	-	-	-	-	1.1	-	-	-	-
	1,2,3,7,8-PeCDD	ND	0.29	0.09	1	0	ND	0.29	0.09	1	0
	PeCDDs	ND	-	-	-	-	0.62	-	-	-	-
	1,2,3,4,7,8-HxCDD	ND	0.6	0.2	0.1	0	ND	0.6	0.2	0.1	0
	1,2,3,6,7,8-HxCDD	ND	0.6	0.2	0.1	0	ND	0.6	0.2	0.1	0
	1,2,3,7,8,9-HxCDD	ND	0.6	0.2	0.1	0	(0.3)	0.6	0.2	0.1	0
	HxCDDs	0.6	-	-	-	-	1.0	-	-	-	-
	1,2,3,4,6,7,8-HpCDD	0.6	0.6	0.2	0.01	0.006	(0.6)	0.6	0.2	0.01	0
	HpCDDs	0.6	-	-	-	-	(0.6)	-	-	-	-
	OCDD	1.9	1.0	0.3	0.0003	0.00057	1.7	1.0	0.3	0.0003	0.00051
	Total PCDFs	3.8	-	-	-	0.0066	4.9	-	-	-	0.00051
PCDFs	1,3,6,8-TeCDF	ND	0.29	0.09	-	-	ND	0.29	0.09	-	0
	1,2,7,8-TeCDF	ND	0.29	0.09	-	-	ND	0.29	0.09	-	0
	2,3,7,8-TeCDF	ND	0.29	0.09	0.1	0	ND	0.29	0.09	0.1	0
	TeCDFs	ND	-	-	-	-	0.39	-	-	-	-
	1,2,3,7,8-TeCDF	(0.10)	0.29	0.09	0.03	0	(0.13)	0.29	0.09	0.03	0
	2,3,4,7,8-TeCDF	ND	0.29	0.09	0.3	0	(0.13)	0.29	0.09	0.3	0
	PeCDFs	0.43	-	-	-	-	0.72	-	-	-	-
	1,2,3,4,7,8-HxCDF	ND	0.6	0.2	0.1	0	(0.2)	0.6	0.2	0.1	0
	1,2,3,6,7,8-HxCDF	ND	0.6	0.2	0.1	0	(0.2)	0.6	0.2	0.1	0
	1,2,3,7,8,9-HxCDF	ND	0.6	0.2	0.1	0	ND	0.6	0.2	0.1	0
	2,3,4,6,7,8-HxCDF	(0.2)	0.6	0.2	0.1	0	(0.2)	0.6	0.2	0.1	0
	HxCDFs	1.0	-	-	-	-	1.3	-	-	-	-
	1,2,3,4,6,7,8-HpCDF	(0.6)	0.6	0.2	0.01	0	0.7	0.6	0.2	0.01	0.007
	1,2,3,4,7,8,9-HpCDF	ND	0.6	0.2	0.01	0	(0.3)	0.6	0.2	0.01	0
HpCDFs	(0.6)	-	-	-	-	0.9	-	-	-	-	
OCDD	(0.1)	1.0	0.3	0.0003	0	1.4	1.0	0.3	0.0003	0.00042	
Total PCDFs	3.0	-	-	-	0	4.7	-	-	-	0.0074	
Total(PCDDs+PCDFs)	6.8	-	-	-	0.0066	9.6	-	-	-	0.0079	
DLPCBs	3,4,4',5-TeCB (#81)	ND	0.6	0.2	0.0003	0	ND	0.6	0.2	0.0003	0
	3,3',4,4'-TeCB (#77)	2.3	0.6	0.2	0.0001	0.00023	(0.2)	0.6	0.2	0.0001	0
	3,3',4,4',5-PeCB (#126)	ND	0.6	0.2	0.1	0	ND	0.6	0.2	0.1	0
	3,3',4,4',5,5'-HxCB (#169)	ND	0.6	0.2	0.03	0	ND	0.6	0.2	0.03	0
	Total non-ortho PCBs	2.3	-	-	-	0.00023	0.2	-	-	-	0
	2',3,4,4',5-PeCB (#123)	(0.4)	0.6	0.2	0.00003	0	ND	0.6	0.2	0.00003	0
	2,3',4,4',5-PeCB (#118)	17	0.6	0.2	0.00003	0.00051	1.1	0.6	0.2	0.00003	0.000033
	2,3,3',4,4'-PeCB (#105)	7.4	0.6	0.2	0.00003	0.000222	(0.4)	0.6	0.2	0.00003	0
	2,3,4,4',5-PeCB (#114)	(0.4)	0.6	0.2	0.00003	0	ND	0.6	0.2	0.00003	0
	2,3',4,4',5,5'-HxCB (#167)	0.7	0.6	0.2	0.00003	0.000021	ND	0.6	0.2	0.00003	0
	2,3,3',4,4',5-HxCB (#156)	1.3	0.6	0.2	0.00003	0.000039	ND	0.6	0.2	0.00003	0
	2,3,3',4,4',5'-HxCB (#157)	(0.4)	0.6	0.2	0.00003	0	ND	0.6	0.2	0.00003	0
	2,3,3',4,4',5,5'-HpCB (#189)	ND	0.6	0.2	0.00003	0	ND	0.6	0.2	0.00003	0
Total mono-ortho PCBs	27	-	-	-	0.00079	1.5	-	-	-	0.000033	
Total DL-PCBs	29	-	-	-	0.0010	1.8	-	-	-	0.000033	
Total ダイオキシン類	36	-	-	-	※0.0076	11	-	-	-	※0.0080	